

Transfer Line Calculation Package

P504 – Los Alamos

June 10, 2019

Overview

The transfer line is used to transfer liquid helium from the liquefier dewars to the target dewar. It is required to deliver 135L to the target dewar. To achieve this 200L will be transferred from the liquefier dewar in 60 minutes.

Contents

Transfer line drawings

The transfer line is entirely vacuum jacketed, and is composed of stingers, flexible sections, valves, and rigid sections. The drawings show the layout and dimensions of the transfer line.

Transfer line losses calculation


Some of the liquid helium that enters the transfer line is lost in the form of helium gas. As a result, the amount of liquid helium that is delivered is reduced. This report estimates the amount of liquid helium that is delivered by calculating the amount of helium that boils-off as a result of: (i) flash boil-off, (ii) cooling down the transfer line, and (iii) heat leak through the transfer line.

Transfer line pressure drop calculation



Helium flowing through the transfer line will result in a pressure drop across the transfer line. This will limit the flow rate of helium. This calculation is used to verify that the size of the transfer line is appropriate to accommodate the required flow of helium.


Transfer line safety

The transfer line contains a cryogenic liquid, as a result, special consideration is required to ensure its safety. The safety calculations include: (i) the sizing of the relief valve, and (ii) the required wall thickness for the helium line.





FULL ASSEMBLY OF TRANSFER LINE

Unless Otherwise Stated: Linear Tol.: ± 0.05 , Angular Tol.: 0.5° Surface Finish: All Dimensions: INCH				PROPRIETARY & CONFIDENTIAL		Projection Method: THIRD ANGLE 	DO NOT SCALE DRAWING	REVISION: 2019-06-10
								
						TITLE: P504 - TRANSFER LINE SOLID		
						DWG NO. P504-TL-021		Sheet Size: A3
						SCALE: 1:40		
						SHEET 1 OF 6		




FLEXIBLE SECTION OF THE INLET OF THE TRANSFER LINE QTY: 3


Unless Otherwise Stated: Linear Tol.: ± 0.2 , Angular Tol.: 0.5° Surface Finish: All Dimensions: INCH				PROPRIETARY & CONFIDENTIAL		Projection Method: THIRD ANGLE 		DO NOT SCALE DRAWING		REVISION: 2019-06-10	
											
								TITLE: P504 - TRANSFER LINE DIMENSIONS			
								DWG NO. P504-TL-022		Sheet Size: A3	
								SCALE: 1:16		SHEET 2 OF 6	


	NAME	SIGNATURE	DATE	NOTES:
DRAWN	R SMITH		2019-06-10	
CHK'D				
APPV'D				



This drawing and any information or descriptive material set out on it are the confidential and copyright property of Quantum Technology and MUST NOT BE DISCLOSED, COPIED, LOANED in whole or part or used for any purpose without the written permission of Quantum Technology.


MATERIAL:	N/A
FINISH:	N/A
WEIGHT:	N/A






Unless Otherwise Stated: Linear Tol.: ± 0.05 , Angular Tol.: 0.5° Surface Finish: All Dimensions: INCH				PROPRIETARY & CONFIDENTIAL		Projection Method: THIRD ANGLE 	DO NOT SCALE DRAWING	REVISION: 2019-06-10
DRAWN R. SMITH				DATE 2019-06-10		TITLE: P504 - TRANSFER LINE DIMENSIONS		
CHK'D				NOTES:		DWG NO. P504-TL-023		
APPV'D				MATERIAL: N/A		Sheet Size: A3		
This drawing and any information or descriptive material set out on it are the confidential and copyright property of Quantum Technology and MUST NOT BE DISCLOSED, COPIED, LOANED in whole or part or used for any purpose without the written permission of Quantum Technology.				FINISH: N/A		SCALE: 1:25		
				WEIGHT: N/A		SHEET 3 OF 6		





Unless Otherwise Stated: Linear Tol.: ± 0.05 , Angular Tol.: 0.5° Surface Finish: All Dimensions: INCH				PROPRIETARY & CONFIDENTIAL		Projection Method: THIRD ANGLE 	DO NOT SCALE DRAWING	REVISION: 2019-06-10
								
						TITLE: P504 - TRANSFER LINE DIMENSIONS		
						DWG NO. P504-TL-024		Sheet Size: A3
						SCALE: 1:15		
						SHEET 4 OF 6		



Unless Otherwise Stated: Linear Tol.: ± 0.05 , Angular Tol.: 0.5° Surface Finish: All Dimensions: INCH				PROPRIETARY & CONFIDENTIAL		Projection Method: THIRD ANGLE 	DO NOT SCALE DRAWING	REVISION: 2019-06-10
								
						TITLE: P504 - TRANSFER LINE DIMENSIONS		
						MATERIAL: N/A	DWG NO. P504-TL-025	Sheet Size: A3
						FINISH: N/A		
						WEIGHT: N/A	SCALE: 1:25	SHEET 5 OF 6



FLEXIBLE SECTION FOR OUTLET OF THE TRANSFER LINE QTY: 1

Unless Otherwise Stated: Linear Tol.: ± 0.2 . Angular Tol.: 0.5° Surface Finish: All Dimensions: INCH				PROPRIETARY & CONFIDENTIAL		Projection Method: THIRD ANGLE 		DO NOT SCALE DRAWING		REVISION: 2019-06-10				
														
	NAME	SIGNATURE	DATE	NOTES:			TITLE: P504 - TRANSFER LINE DIMENSIONS							
DRAWN	R SMITH		2019-06-10											
CHK'D														
APPV'D														
This drawing and any information or descriptive material set out on it are the confidential and copyright property of Quantum Technology and MUST NOT BE DISCLOSED, COPIED, LOANED in whole or part or used for any purpose without the written permission of Quantum Technology.														
				MATERIAL:			N/A			DWG NO.		Sheet Size:		
				FINISH:			N/A			P504-TL-026		A3		
				WEIGHT: N/A						SCALE: 1:16		SHEET 6 OF 6		

Transfer line losses

P504 - Los Alamos

Jan 29, 2019

Stefan S-G

The liquid helium transfer line is designed to transfer 200L Lhe (before losses) in 60 min

This report estimates the amount of liquid delivered by calculating the amount of helium that boils-off as a result of:

- flash boil-off
- cool down of the rigid line, flexible lines, bayonets and valves
- heat leak through the rigid line, flexible lines, bayonets and valves

Transfer properties

Transfer volume $V := 200 \text{ L}$

Transfer duration $t := 60 \text{ min}$

Liquid density $\rho_{liquid} := 124.3 \frac{\text{kg}}{\text{m}^3}$

Flash boil-off

As the helium is transferred, it moves from higher pressure to lower pressure. This results in some of the helium boiling off. A pressure drop of 6psi with no subcooling of the helium is considered to be conservative.

Enthalpy of saturated liquid at 23 psia $H_{liquid1} := 3.33 \frac{\text{kJ}}{\text{kg}}$

Enthalpy of saturated liquid at 17 psia $H_{liquid2} := 0.901 \frac{\text{kJ}}{\text{kg}}$

Enthalpy of saturated vapor at 17 psia $H_{vapor2} := 20.66 \frac{\text{kJ}}{\text{kg}}$

Percentage boil-off $x := \frac{H_{liquid1} - H_{liquid2}}{H_{vapor2} - H_{liquid2}} = 0.1229$

Boil-off volume $V_{flash} := x \cdot V = 24.5863 \text{ L}$

Cool Down Losses

Before the transfer the transfer line is at 300K. The transfer line is cooled by flowing liquid helium into the transfer line. This calculation assumes that the helium temperature at the outlet is 50K. The assumption is not valid for the final cooling of the transfer line, however, the heat required for this is relatively small.

Material properties

Density 304 SS	$\rho_{ss} := 7900 \frac{\text{kg}}{\text{m}^3}$
Integrated heat capacity (4K to 300K for ss 304) (trc.nist.gov/cryogenics/materials)	$C_{ss} := 92.2 \frac{\text{kJ}}{\text{kg}}$
Helium Gas Enthalpy at 50K	$H_{\text{vapor}3} := 265 \frac{\text{kJ}}{\text{kg}}$
Helium heat	$\Delta H_{\text{He}} := H_{\text{vapor}3} - H_{\text{liquid}2} = 264.099 \frac{\text{kJ}}{\text{kg}}$

Rigid Line Cool Down

Length of rigid line	$L_{\text{rigid}} := 38.5 \text{ ft}$
Tubing OD	$OD := 0.375 \text{ in}$
Tubing wall thickness	$t_{\text{wall}} := 0.02 \text{ in}$
Tubing ID	$ID := OD - 2 \cdot t_{\text{wall}} = 0.335 \text{ in}$
Cross section area	$A := \frac{\pi}{4} \cdot \left(OD^2 - (OD - 2 \cdot t_{\text{wall}})^2 \right) = 1.439 \cdot 10^{-5} \text{ m}^2$
Mass of tubing	$M_{\text{tubing}} := L_{\text{rigid}} \cdot A \cdot \rho_{ss} = 1.3341 \text{ kg}$
Boil-off	$V_{\text{rigid}} := \frac{M_{\text{tubing}} \cdot C_{ss}}{\Delta H_{\text{He}} \cdot \rho_{\text{liquid}}} = 3.7469 \text{ L}$

Valve Cool Down

Number of valves	$N_{\text{valve}} := 4$
Mass of valves	$M_{\text{valve}} := 0.18 \text{ lb}$
Boil-off	$V_{\text{valve}} := \frac{N_{\text{valve}} \cdot M_{\text{valve}} \cdot C_{ss}}{\Delta H_{\text{He}} \cdot \rho_{\text{liquid}}} = 0.9173 \text{ L}$

Flexible Line Cool Down

Inner Flexible Line Mass per length	$m_{\text{flex}} := 0.04 \frac{\text{lb}}{\text{ft}}$
Length flexible Line	$L_{\text{flex}} := 16 \text{ ft}$
Mass of inner flexible line	$M_{\text{flex}} := m_{\text{flex}} \cdot L_{\text{flex}} = 0.2903 \text{ kg}$
Boil-off	$V_{\text{flex}} := \frac{M_{\text{flex}} \cdot C_{ss}}{\Delta H_{\text{He}} \cdot \rho_{\text{liquid}}} = 0.8153 \text{ L}$

Bayonet Cool Down

$$\text{Number of bayonets} \quad N_{\text{bayonet}} := 4$$

$$\text{Mass of bayonet} \quad M_{\text{bayonet}} := 0.8 \text{ lb}$$

$$\text{Boil-off} \quad V_{\text{bayonet}} := \frac{N_{\text{bayonet}} \cdot M_{\text{bayonet}} \cdot C_{ss}}{\Delta H_{\text{He}} \cdot \rho_{\text{liquid}}} = 4.0767 \text{ L}$$

Transfer Line Cooling

Total Boil-off

$$V_{\text{cooling}} := V_{\text{rigid}} + V_{\text{valve}} + V_{\text{flex}} + V_{\text{bayonet}} = 9.5562 \text{ L}$$

Transfer Losses

During the transfer additional helium is lost as a result of heat leak

$$\text{Helium Latent Heat} \quad L_{\text{He}} := H_{\text{vapor2}} - H_{\text{liquid2}} = 19.759 \frac{\text{kJ}}{\text{kg}}$$

Rigid line

$$\text{Rigid line heat leak} \quad Q_{\text{rigid}} := 0.6 \frac{\text{BTU}}{\text{hr ft}} \cdot L_{\text{rigid}} = 6.7699 \text{ W}$$

Flexible line

$$\text{Flexible line heat leak} \quad Q_{\text{flex}} := 0.71 \frac{\text{BTU}}{\text{hr ft}} \cdot L_{\text{flex}} = 3.3293 \text{ W}$$

Bayonet

$$\text{Bayonet heat leak} \quad Q_{\text{bayonet}} := N_{\text{bayonet}} \cdot 4.3 \frac{\text{BTU}}{\text{hr}} = 5.0408 \text{ W}$$

Valve

$$\text{Valve Heat leak} \quad Q_{\text{valve}} := N_{\text{valve}} \cdot 3.1 \frac{\text{BTU}}{\text{hr}} = 3.6341 \text{ W}$$

Total Heat Leak

$$Q_{\text{total}} := Q_{\text{rigid}} + Q_{\text{flex}} + Q_{\text{bayonet}} + Q_{\text{valve}} = 18.7741 \text{ W}$$

Rate He Loss

$$V_{\text{rate}} := \frac{Q_{\text{total}}}{L_{\text{He}} \cdot \rho_{\text{liquid}}} = 27.5186 \frac{\text{L}}{\text{hr}}$$

Summary

$$\text{Flash boil-off} \quad V_{\text{flash}} = 24.5863 \text{ L}$$

$$\text{Cool down losses} \quad V_{\text{cooling}} = 9.5562 \text{ L}$$

$$\text{Transfer losses} \quad V_{\text{rate}} = 27.5186 \frac{\text{L}}{\text{hr}}$$

Total Helium Delivered

$$V - V_{\text{flash}} - V_{\text{cooling}} - V_{\text{rate}} \cdot t = 138.3389 \text{ L}$$

Transfer line pressure drop

P504 - Los Alamos

Jan 29, 2019

Stefan S-G

The liquid helium transfer line is designed to transfer 200L LHe (before losses) in 60 min

The transfer line consists of the following components:

- Inlet stinger: 48", 1/2" outer tube, 5/16" (0.02" wall) inner tube
- Inlet flex line: 8 ft, inner tube 3/8" flex
- Rigid transfer line: 38.5 ft, 3/8" (0.02" wall) inner tube
- Outlet flex line: 8 ft, inner tube 3/8" flex
- Outlet stinger: 18", 3/8" outer tube, 3/16" (0.016" wall) inner tube

The calculation for pressure drop in two phase helium flow is as described in Chang et al "Pressure drop of two-phase helium along long cryogenic flexible transfer lines...", 2016

A conservative approach is taken by assuming the flow consists of the highest gas fraction for the entire length of the transferline. See "Transfer Line Losses" for boiloff calculations. This calculation does not account for the inclination of the transfer line minor losses at inlets, outlets, transitions, elbows, and valves.

Flow properties

Batch volume	$V_{batch} := 200 \text{ L}$
Cool down volume	$V_{cooling} := 10 \text{ L}$
Transfer volume	$V_{transfer} := V_{batch} - V_{cooling}$
Amount of boil off	$V_{boiloff} := 50 \text{ L}$
Density	$\rho_l := 124.3 \frac{\text{kg}}{\text{m}^3} \quad \rho_g := 17.12 \frac{\text{kg}}{\text{m}^3}$
Liquid volume	$V_l := V_{transfer} - V_{boiloff} = 140 \text{ L}$
Gas volume	$V_g := V_{boiloff} \cdot \frac{\rho_l}{\rho_g} = 363.0257 \text{ L}$
Gas Volume Fraction	$x := \frac{V_{boiloff}}{V_{transfer}} = 0.2632$
Density	$\rho := \frac{1}{\frac{x}{\rho_g} + \frac{(1-x)}{\rho_l}} = 46.9499 \frac{\text{kg}}{\text{m}^3}$
Transfer duration	$t := 60 \text{ min}$
Volume flow rate	$Q := \frac{V_l + V_g}{t} = 0.0001 \frac{\text{m}^3}{\text{s}}$
Viscosity	$\mu_l := 3.15 \cdot 10^{-6} \text{ Pa s} \quad \mu_g := 1.26 \cdot 10^{-6} \text{ Pa s}$
Surface roughness of ss	$\varepsilon := 0.002 \text{ mm}$

Inlet Stinger

Tubing OD

$$OD := \frac{5}{16} \text{ in}$$

Tubing wall thickness

$$t_{wall} := 0.02 \text{ in}$$

Length

$$L := 48 \text{ in}$$

Tubing ID

$$ID := OD - 2 \cdot t_{wall} = 0.2725 \text{ in}$$

Velocity

$$v := \frac{Q}{\frac{\pi}{4} \cdot ID^2} = 3.7136 \frac{\text{m}}{\text{s}}$$

Reynolds number

$$Re_g := \frac{ID \cdot v \cdot \rho_g}{\mu_g} = 3.4925 \cdot 10^5 \quad Re_l := \frac{ID \cdot v \cdot \rho_l}{\mu_l} = 1.0143 \cdot 10^6$$

Friction factor

$$Re := \frac{x^2 + (1-x)^2 \cdot \left(\frac{\rho_g}{\rho_l} \right)}{\frac{x^2}{Re_g} + \left(\frac{(1-x)^2}{Re_l} \right) \cdot \frac{\rho_g}{\rho_l}} = 5.2949 \cdot 10^5$$

$$f := \left(\frac{1}{(-2) \cdot \log_{10} \left(\frac{1}{3.7065} \cdot \frac{\varepsilon}{ID} - \frac{5.0452}{Re} \cdot \log_{10} \left(\frac{1}{2.8257} \cdot \left(\frac{\varepsilon}{ID} \right)^{1.1098} + \frac{5.8506}{Re^{0.8981}} \right) \right) \right)^2 = 0.0162$$

Pressure drop

$$\Delta P_{IS} := \frac{1}{2} \cdot f \cdot \rho \cdot v^2 \cdot \frac{L}{ID} = 0.1337 \frac{\text{lbf}}{\text{in}^2}$$

Inlet Flex

Tubing OD

$$OD := 0.375 \text{ in}$$

Tubing wall thickness

$$t_{wall} := 0.02 \text{ in}$$

Length

$$L := 8 \text{ ft}$$

Tubing ID

$$ID := OD - 2 \cdot t_{wall} = 0.335 \text{ in}$$

Velocity

$$v := \frac{Q}{\frac{\pi}{4} \cdot ID^2} = 2.4572 \frac{\text{m}}{\text{s}}$$

Reynolds number

$$Re_g := \frac{ID \cdot v \cdot \rho_g}{\mu_g} = 2.8409 \cdot 10^5 \quad Re_l := \frac{ID \cdot v \cdot \rho_l}{\mu_l} = 8.2505 \cdot 10^5$$

$$Re := \frac{\frac{x^2 + (1-x)^2 \cdot \left(\frac{\rho_g}{\rho_l}\right)}{\frac{x^2}{Re_g} + \left(\frac{(1-x)^2}{Re_l}\right) \cdot \frac{\rho_g}{\rho_l}}}{\rho_l} = 4.3071 \cdot 10^5$$

Friction factor

corrugated pipe

$$f := 0.08$$

Pressure drop

$$\Delta P_{IF} := \frac{1}{2} \cdot f \cdot \rho \cdot v^2 \cdot \frac{L}{ID} = 0.4713 \frac{\text{lbf}}{\text{in}^2}$$

RigidTubing OD $OD := 0.375 \text{ in}$ Tubing wall thickness $t_{wall} := 0.02 \text{ in}$ Length $L := 38.5 \text{ ft}$ Tubing ID $ID := OD - 2 \cdot t_{wall} = 0.335 \text{ in}$ Velocity $v := \frac{Q}{\frac{\pi}{4} \cdot ID^2} = 2.4572 \frac{\text{m}}{\text{s}}$ Reynolds number $Re_g := \frac{ID \cdot v \cdot \rho_g}{\mu_g} = 2.8409 \cdot 10^5$ $Re_l := \frac{ID \cdot v \cdot \rho_l}{\mu_l} = 8.2505 \cdot 10^5$ Friction factor $Re := \frac{x^2 + (1-x)^2 \cdot \left(\frac{\rho_g}{\rho_l} \right)}{\frac{x^2}{Re_g} + \left(\frac{(1-x)^2}{Re_l} \right) \cdot \frac{\rho_g}{\rho_l}} = 4.3071 \cdot 10^5$

$$f := \left(\frac{1}{(-2) \cdot \log_{10} \left(\frac{1}{3.7065} \cdot \frac{\varepsilon}{ID} - \frac{5.0452}{Re} \cdot \log_{10} \left(\frac{1}{2.8257} \cdot \left(\frac{\varepsilon}{ID} \right)^{1.1098} + \frac{5.8506}{Re^{0.8981}} \right) \right) \right)^2 = 0.016$$

Pressure drop $\Delta P_R := \frac{1}{2} \cdot f \cdot \rho \cdot v^2 \cdot \frac{L}{ID} = 0.4533 \frac{\text{lbf}}{\text{in}^2}$

Outlet Flex

Tubing OD $OD := 0.375 \text{ in}$

Tubing wall thickness $t_{wall} := 0.02 \text{ in}$

Length $L := 8 \text{ ft}$

Tubing ID $ID := OD - 2 \cdot t_{wall} = 0.335 \text{ in}$

Velocity $v := \frac{Q}{\frac{\pi}{4} \cdot ID^2} = 2.4572 \frac{\text{m}}{\text{s}}$

Reynolds number $Re_g := \frac{ID \cdot v \cdot \rho_g}{\mu_g} = 2.8409 \cdot 10^5$ $Re_l := \frac{ID \cdot v \cdot \rho_l}{\mu_l} = 8.2505 \cdot 10^5$

$$Re := \frac{x^2 + (1-x)^2 \cdot \left(\frac{\rho_g}{\rho_l} \right)}{\frac{x^2}{Re_g} + \left(\frac{(1-x)^2}{Re_l} \right) \cdot \frac{\rho_g}{\rho_l}} = 4.3071 \cdot 10^5$$

Friction factor
corrugated pipe $f := 0.08$

Pressure drop $\Delta P_{OF} := \frac{1}{2} \cdot f \cdot \rho \cdot v^2 \cdot \frac{L}{ID} = 0.4713 \frac{\text{lbf}}{\text{in}^2}$

Outlet Stinger

Tubing OD $OD := \frac{3}{16} \text{ in}$

Tubing wall thickness $t_{wall} := 0.016 \text{ in}$

Length $L := 18 \text{ in}$

Tubing ID $ID := OD - 2 \cdot t_{wall} = 0.1555 \text{ in}$

Velocity $v := \frac{Q}{\frac{\pi}{4} \cdot ID^2} = 11.4043 \frac{\text{m}}{\text{s}}$

Reynolds number $Re_g := \frac{ID \cdot v \cdot \rho_g}{\mu_g} = 6.1202 \cdot 10^5 \quad Re_l := \frac{ID \cdot v \cdot \rho_l}{\mu_l} = 1.7774 \cdot 10^6$

$$Re := \frac{x^2 + (1-x)^2 \cdot \left(\frac{\rho_g}{\rho_l} \right)}{\frac{x^2}{Re_g} + \left(\frac{(1-x)^2}{Re_l} \right) \cdot \frac{\rho_g}{\rho_l}} = 9.2789 \cdot 10^5$$

Friction factor

$$f := \left(\frac{1}{(-2) \cdot \log_{10} \left(\frac{1}{3.7065} \cdot \frac{\varepsilon}{ID} - \frac{5.0452}{Re} \cdot \log_{10} \left(\frac{1}{2.8257} \cdot \left(\frac{\varepsilon}{ID} \right)^{1.1098} + \frac{5.8506}{Re^{0.8981}} \right) \right)} \right)^2 = 0.0173$$

Pressure drop $\Delta P_{OS} := \frac{1}{2} \cdot f \cdot \rho \cdot v^2 \cdot \frac{L}{ID} = 0.8872 \frac{\text{lbf}}{\text{in}^2}$

Total

$$\Delta P := \Delta P_{IS} + \Delta P_{IF} + \Delta P_R + \Delta P_{OF} + \Delta P_{OS} = 2.4168 \frac{\text{lbf}}{\text{in}^2}$$

Transfer line safety

P504 - Los Alamos

June 5, 2019

Stefan S-G, QTC

Relief valve sizing

The rigid section of the transfer line is located between two valves. If these valves are shut they can trap liquid helium in the transfer line. The transfer line is equipped with two pressure relief valves (one on either end) to vent the resulting boil-off. The rate of boil-off is determined by the heat load. A loss in insulating vacuum will result in the largest heat load and therefore, the largest rate of boil-off. This report considers a loss of insulating vacuum in each of the sections of the transfer line independently.

Helium tube OD	$OD := \frac{3}{8} \text{ in} = 0.0095 \text{ m}$
Atmospheric pressure	$P_{atm} := 14.7 \text{ psi}$
Relief valve pressure (Generant CRV-4-FS-10)	$P_{relief} := 10 \text{ psi}$
Helium latent heat at 24.7 psia	$\Delta H := (19.5 - 4.08) \frac{\text{kJ}}{\text{kg}} = 15.42 \frac{\text{kJ}}{\text{kg}}$
Density of saturated helium gas at 24.7 psia	$\rho_{gas} := 30.7 \frac{\text{kg}}{\text{m}^3}$
Viscosity	$\mu := 1.26 \cdot 10^{-6} \text{ Pa s}$
Heat flux (for LHe cryostat with 10mm MLI W. Lehmann & G. Zahn safety aspects for LHe cryostats IPC Science & Technology (1978) 569-579)	$q := 5000 \frac{\text{W}}{\text{m}^2}$
Upper section	
Length	$L_{upper} := 150 \text{ in}$
Tube surface area	$A_{upper} := \pi \cdot OD \cdot L_{upper} = 0.114 \text{ m}^2$
Heat transfer	$Q_{upper} := q \cdot A_{upper} = 570.0459 \text{ W}$
Mass rate of boil off	$\dot{W}_{upper} := \frac{Q_{upper}}{\Delta H} = 0.037 \frac{\text{kg}}{\text{s}}$
Middle section	
Length	$L_{middle} := 161 \text{ in}$
Tube surface area	$A_{middle} := \pi \cdot OD \cdot L_{middle} = 0.1224 \text{ m}^2$
Heat transfer	$Q_{middle} := q \cdot A_{middle} = 611.8493 \text{ W}$
Mass rate of boil off	$\dot{W}_{middle} := \frac{Q_{middle}}{\Delta H} = 0.0397 \frac{\text{kg}}{\text{s}}$
Lower section	
Length	$L_{lower} := 159 \text{ in}$
Tube surface area	$A_{lower} := \pi \cdot OD \cdot L_{lower} = 0.1208 \text{ m}^2$
Heat transfer	$Q_{lower} := q \cdot A_{lower} = 604.2487 \text{ W}$
Mass rate of boil off	$\dot{W}_{lower} := \frac{Q_{lower}}{\Delta H} = 0.0392 \frac{\text{kg}}{\text{s}}$

A loss in insulating vacuum of the middle section of the transferline produces the largest mass boil-off. This mass boil off is therefore used to determine the required relief valve size.

The required relief valve area is calculated from
 "Sizing Pressure-Relief Devices - American Institute of Chemical Engineers"
 (https://www.aiche.org/sites/default/files/cep/20131068_r.pdf)

Compressibility factor	$Z := 1$
Temperature	$T := 4.8 \text{ K}$
Heat capacity ratio	$\gamma := 1.66$
Gas constant	$R_g := 8.314 \frac{\text{J}}{\text{K mol}}$
Factor for simplification	$C := \sqrt{\frac{\gamma}{R_g} \cdot \left(\frac{2}{\gamma + 1} \right)^{(\gamma + 1) \cdot (\gamma - 1)}}$
Discharge coefficient (Generant CRV-4-FS-10)	$K_d := 0.44$
Relieving pressure (absolute, 10% back pressure)	$P_l := P_{atm} + 1.1 \cdot P_{relief} = 1.772 \cdot 10^5 \text{ Pa}$
Backpressure adjustment factor	$K_b := 1$
molecular weight	$M := 4.02 \frac{\text{g}}{\text{mol}}$
require area	$A_{relief} := \frac{W_{middle}}{C \cdot K_d \cdot P_l \cdot K_b} \cdot \sqrt{\frac{T \cdot Z}{M}} = 5.0551 \cdot 10^{-5} \text{ m}^2$
required area per relief valve	$A_{rv} := \frac{A_{relief}}{2}$
Required diameter	$d := \sqrt{\frac{4 \cdot A_{rv}}{\pi}} = 0.2233 \text{ in}$
Relief valve orifice (Generant CRV-4-FS-10)	$d_{orifice} := 0.312 \text{ in}$

Required tube wall thickness

The required wall thickness for the helium line is determined based on the maximum pressure that could potentially be seen by the helium line.

The maximum pressure in the transfer line would result from a loss of vacuum insulation. In this case the liquid helium in the transfer line would boil-off rapidly. The helium gas would travel through the helium line to the relief valve. The helium line would resist the flow of helium and result in a build of pressure.

The middle section of the transfer line is furthest from the relief valves so a loss of vacuum in this section results in the largest pressure. In this case the boil-off is released equally through each relief valve. The calculations below determines the maximum pressure that would result due to half of boil-off being released through the lower relief valve. This will equal the maximum pressure in the system by the symmetry.

Mass rate of boil off	$m_{boiloff} := \frac{\dot{W}_{middle}}{2} = 0.0198 \frac{kg}{s}$
-----------------------	---

Volume rate of boil off	$V_{boiloff} := \frac{m_{boiloff}}{\rho_{gas}} = 1.3693 \frac{ft^3}{min}$
-------------------------	---

wall thickness	$t_{wall} := 0.02 \text{ in}$
----------------	-------------------------------

Internal diameter	$ID := OD - 2 \cdot t_{wall} = 0.0085 \text{ m}$
-------------------	--

Velocity in tube	$v := \frac{V_{boiloff}}{\frac{\pi}{4} \cdot ID^2} = 11.3644 \frac{m}{s}$
------------------	---

Reynolds number	$Re := \frac{\rho_{gas} \cdot v \cdot ID}{\mu} = 2.3561 \cdot 10^6$
-----------------	---

Surface roughness (typical value for ss)	$\varepsilon := 0.002 \text{ mm}$
---	-----------------------------------

Friction factor	$f := \left(-1.8 \cdot \log_{10} \left(\frac{6.9}{Re} + \left(\frac{\varepsilon}{ID} \right)^{1.11} \right) \right)^{-2} = 0.0146$
-----------------	---

Pressure drop in tube	$P_{tube} := \frac{1}{2} \cdot \rho_{gas} \cdot v^2 \cdot \frac{L_{lower}}{ID} \cdot f = 1.9868 \text{ psi}$
-----------------------	--

Maximum pressure in helium line	<table border="1"><tr><td>$P_{max} := P_{relief} \cdot 1.1 + P_{tube} = 12.9868 \text{ psi}$</td></tr></table>	$P_{max} := P_{relief} \cdot 1.1 + P_{tube} = 12.9868 \text{ psi}$
$P_{max} := P_{relief} \cdot 1.1 + P_{tube} = 12.9868 \text{ psi}$		

Required wall thickness coefficient calculations as per ASME B31.1-2016

Allowable stress for ss 304 $\sigma_{allow} := 138 \text{ MPa}$
(Table A-1M)

Pressure relative to vacuum space $P_{gauge} := P_{max} + P_{atm} = 27.6868 \text{ psi}$

Longitudinal weld joint quality factor $E := 1$
for seamless tube (Table A-1B)

Wall thickness coefficient $Y := 0.4$
(Table 304.1.1)

Weld joint strength reduction factor $W := 1$
(Table 302.3.5)

Required wall thickness
(equation 3a)

$$t := \frac{P_{gauge} \cdot OD}{2 \cdot (\sigma_{allow} \cdot E \cdot W + P_{gauge} \cdot Y)} = 0.0003 \text{ in}$$

Actual minimum wall thickness

$$t_{min} := t_{wall} \cdot 0.875 = 0.0175 \text{ in}$$